



# Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, 3RD FLOOR, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.774.9587

[HTTP://DPP.VI.GOV](http://DPP.VI.GOV)



May 10, 2019

## **AMENDMENT #3--IFB021BOCC19 (C)-Roof Repairs to the Golden Grove Adult Correctional Facility & Detention Center on St. Croix, U. S. Virgin Islands**

### **INSERT:           QUESTIONS AND ANSWERS**

**Question:** As it relates to some parts of the membrane roof; will we be responsible for scraping up the frayed layers (when it applies) of mesh, existing hypalon and other existing layers to get a surface that is adequate for applying the roll-on membrane?

**Response:** Yes, it is required that the contractor remove and dispose of frayed layer of mesh, hypalon and other exiting layers to attain a good bond of adherence of new product to roof surface.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

A COPY OF THIS AMMENDMENT MUST BE RETURNED WITH YOUR BID